

GEMCOM, INC

8828 S. Archer Avenue
Willow Springs, IL 60480
(800) 871-6840 or (888)-4GEMCOM (436266)
Fax (708) 839-0324

AGENT ABORT SWITCH

The abort switch provides a temporary manual means for interrupting the agent actuation circuit between the initial alarm and automatic release. The panel employs a momentary dead-man type switch which, when pressed, opens the actuator circuit by interrupting electric current.

Each switch has (2) led indicators: "System On" and "System Aborted" which indicate the condition of the system.

The information is silk-screened on a two-gang stainless steel plate. The panel mounts on a two-gang deep bell box or a two-gang deep wire mold box and operates on 24VDC. These panels can be flush mounted with a two-gang plaster ring on a 4" square 1900 box.

Rated at 10A 250VAC, 15A 125-250VAC, the DC rating is 15A up to 30VDC.

**YourLogo
Here**

